

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	Select School District.
School Name:	School District #81 All locations
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes Choose an item. Date of last inspection: Sept 2025 Click to enter a date. Date of next inspection: Jan. 2026 Click to enter a date. Date and type of most recent maintenance: Filter Change + Grease motor + shafts
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes Choose an item. Detail: As much as DDC Allows for Ambient
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes Choose an item. Detail (Including filter grade): MERV 8.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: Yes Choose an item. Detail: GPS Global Plasma Solutions
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes Choose an item. Detail: Reliable Controls DDC.
Other Relevant Information:	
District Contact for any Questions:	Name: DARRYL LOW Phone Number: 250-500-2334 Email: Dlow@sd81.bc.ca.